



EQUIPMENT LIST		
ITEM	QTY.	DESCRIPTION
1	1	GRUNDFOS PUMP TYPE: CR 64-1-1 60 HZ
2	2	RAYPAK HIDELTA BOILER MODEL NO.: 2072B
3	1	WESSELS AIR SEPARATOR MODEL NO.: SPA-4
4	2	WESSELS EXPANSION TANK MODEL NO.: NTA-80
5	4	WATTS 2-1/2" BUTTERFLY VALVE WITH 10 POSITION LEVER
6	1	AXIOM INDUSTRIES GLYCOL MAKEUP FEEDER MODEL# MF200
7	1	RAYPACK COLD START MIXING VALVE MODEL# 012232
8	2	RAYPACK T&P GAUGE MODEL# 007205F
9	2	WATTS 4" BUTTERFLY VALVE WITH 10 POSITION LEVER
10	1	DONGAN ELECTRIC MFG. CO. TRANSFORMER ITEM# 26512 85-1055SH DON 5KVA 1PH GP 3R ENCAP

LEGEND:

T = THERMOSTAT

☒ = MANIFOLD

● = SLAB SENSOR

NOTE:

1. ALL CIRCUIT LENGTHS INCLUDE A 5' SUPPLY AND A 5' RETURN ALLOWANCE FOR RISERS TO MANIFOLD AND PLACEMENT TOLERANCE.

2. ALL THERMOSTAT LOCATIONS ARE APPROXIMATE, MUST BE APPROVED BY OWNER.

3. CONTRACTOR TO VERIFY DIMENSIONS IN FIELD.

LIABILITY

This drawing and our recommendations and suggestions, are intended to assist our customers. Our design represents our best judgment based on our experience and the best facts provided to us, any use thereof is at the sole risk of the customer.

It is assumed that the customer will install the THAW-PAK system in compliance with all local, state and national codes.